

Changzhou Huayao Photovoltaic
Technology Co., Ltd.
Lijuan Fan

Date : 06.06.2022
Our ref. : Liud 01
Your ref.: L.J.F

No.266 Yaotang Road, Yaotang Street
Jintan, Changzhou
213213 Jiangsu
P.R. China

Ref : PV Photovoltaic Modules

Type of Equipment : PV Module
Model Designation : See Certificate
Certificate No. : PV 50546370 0001
Report No. : CN22D5AF 001

Dear Lijuan Fan,

Thank you very much for your interest in our services.

Please find enclosed your certification documents.

We appreciate your support and would like to offer our assistance in the approval of your future products through our extensive range of technical services.

Please feel free to contact us whatever your requirements may be.

With kind regards,

Certification Body

Dipl.-Ing. (FH) F. He

cc: Changzhou Huayao Photovoltaic

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
PV 50546370

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
L.J.F

Unser Zeichen *Our Reference*
01-Liud-CN22D5AF 001

Ausstellungsdatum *Date of Issue*
06.06.2022 (day/mo/yr)

Genehmigungsinhaber *License Holder*
Changzhou Huayao Photovoltaic
Technology Co.,Ltd.
No.266 Yaotang Road, Yaotang Street
Jintan, Changzhou
213213 Jiangsu
P.R. China

Fertigungsstätte *Manufacturing Plant*
Refer to latest revision
of the annex list of factories

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*

IEC 61215-1:2021
IEC 61215-1-1:2021
IEC 61215-2:2021
IEC 61730-1:2016
IEC 61730-2:2016
EN IEC 61215-1:2021
EN IEC 61215-1-1:2021
EN IEC 61215-2:2021
EN IEC 61730-1:2018
EN IEC 61730-2:2018

**Zertifiziertes Produkt (Geräteidentifikation)
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit
*License Fee - Unit***

PV Module

Type Designation:
Max. System voltage: 1500V
With 1/2 cut of mono c-Si cells:
HYxxx-M144BSS (xxx = 530-550, in steps of 5, 144 cells)
HYxxx-M120BSS (xxx = 440-455, in steps of 5, 120 cells)
HYxxx-M108BSS (xxx = 395-410, in steps of 5, 108 cells)
HYxxx-M132CSS (xxx = 645-670, in steps of 5, 132 cells)
HYxxx-M120CSS (xxx = 580-610, in steps of 5, 120 cells)

Remarks:
Class II acc. to IEC 61140
Fire Rating: Class C according to UL790.
Design Load / Safety Factors: 3600 Pa / 1.5 (downward)
1600 Pa / 1.5 (upward)

Conditions:
The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.
The certificate is valid until 05 June 2027.

*Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product fulfills above mentioned requirements, the production is subject to surveillance.*



Zertifizierungsstelle

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
<http://www.tuv.com/safety> E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

Dipl.-Ing. (FH) F. He

Anlage Fertigungsstättenliste
/Attachment List of Factories



PV 50546370 0001

1 Changzhou RIX Photovoltaic
Technology Co., Ltd.
No.21 Changhu Road,
Rulin Town, Jintan District
Changzhou,
Jiangsu
P.R. China



TÜVRheinland®

Dieser Anhang ersetzt den Vorgänger vom/
This annex replaces the previous annex dated

Datum / Date 06.06.2022



Zertifizierungsstelle
/ Certification Body

Dipl.-Ing. (FH) F. He