

ANNUAL SUMMARY FOR REPORTING PERIOD EPA licence 2636 Anniversary date 16 June

Date	Pollutant	Units of measure	Monitoring Frequency required by licence	No. of times measured during year	Min.value	Max. Value	MEAN	90 percentile limit	Exceedence YES/NO
	Biochemical Oxygen demand	mg per litre	Every 6 months	2	<2	<2	<2	10	no
16-Jun-22	Nitrogen (Total)	mg per litre	Every 6 months	2	0.4	0.6	0.5	NA	
16-Jun-22	Phosphorus (Total)	mg per litre	Every 6 months	2	0.09	0.15	0.12	NA	
16-Jun-22	Total dissolved solids	mg per litre	Every 6 months	2	20	58	39	NA	
16-Jun-22	Total suspended solids	mg per litre	Every 6 months	2	14	22	18	NA	