

# CERTIFICATE

**TÜV NORD CERT GmbH**  
herewith declares that

**Suzhou Akcome Optronics Science & Technology Co., Ltd.**  
Jintang Rd, Zhangjiagang Economic Development Zone  
Zhangjiagang City, Jiangsu Province, 215618  
P.R. China

is authorized to provide the product mentioned below with the mark as illustrated:

**Description of product (details see Annex 2):**

**PV Modules with 6" Mono-crystalline Silicon Solar Cells**

**PV Modules with half-cut 6" Mono-crystalline Silicon Solar Cells**

**PV Modules with half-cut 7" Mono-crystalline Silicon Solar Cells**

**PV Modules with half-cut 8" Mono-crystalline Silicon Solar Cells**



Valid from: 2021-09-23

Valid until: 2023-10-11

Certification program:	P12-VA-01 Rev. 17 09.20
Certification fundamental(s):	IEC / EN 61215-1:2016; IEC / EN 61215-1-1:2016; IEC 61215-2:2016 / EN 61215-2:2017 + AC:2017 + AC:2018; IEC 61730-1:2016 / EN IEC 61730-1:2018 + AC:2018; IEC 61730-2:2016 / EN IEC 61730-2:2018 + AC:2018.
Registered No.:	44 780 19 406749 - 422R5A2M7
Manufacturer:	see Annex 1
Test Report No.:	492011121.011
File No.:	PVP03086/21P-02



**TÜV NORD CERT GmbH**  
**Certification Body**  
**Consumer Products**



Essen, 2021-09-23

Please also pay attention to the information stated overleaf.

**Manufacturer:**

Manufacturer 1: **Suzhou Akcome Optronics Science & Technology Co., Ltd.**  
Jintang Rd, Zhangjiagang Economic Development Zone  
Zhangjiagang City, Jiangsu Province, 215618, P.R. China

Factory inspection report no.: 862010243.008

Manufacturer 2: **Zhejiang Akcome Optronics Science&Technology Co., Ltd.**  
Zheneng Science and Technology Industrial Park, Meishan Town  
Changxing, Huzhou City, Zhejiang, P.R.China

Factory inspection report no.: 862010481.002

**Remark:**

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.



**Description of product(s):**

Module types:	<b>PV Modules with 6" Mono-crystalline Silicon Solar Cells:</b> 78 cells: SK6613MHV-xxx (xxx = 405-420, in increment of 5) 72 cells: SK6612MHV-xxx (xxx = 320-395, in increment of 5) 66 cells: SK6611MHV-xxx (xxx = 310-355, in increment of 5) 60 cells: SK6610MHV-xxx (xxx = 280-325, in increment of 5) 54 cells: SK6609MHV-xxx (xxx = 250-290, in increment of 5) 48 cells: SK6608MHV-xxx (xxx = 220-260, in increment of 5)
Maximum system voltage:	1500V
Fuse rating:	20A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I or IIIa
Design load (positive / negative):	3600Pa / 1600Pa
Safety factors:	1.5
Fire safety class:	Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)



Module types:	<b>PV Modules with half-cut 6" Mono-crystalline Silicon Solar Cells:</b> 144 cells: SK6612MHVC-xxx (xxx = 370-425, in increment of 5) 132 cells: SK6611MHVC-xxx (xxx = 355-390, in increment of 5) 120 cells: SK6610MHVC-xxx (xxx = 310-355, in increment of 5) 144 cells: SK8612MHVC-xxx (xxx = 420-460, in increment of 5) 132 cells: SK8611MHVC-xxx (xxx = 385-420, in increment of 5) 120 cells: SK8610MHVC-xxx (xxx = 350-380, in increment of 5) 108 cells: SK8609MHVC-xxx (xxx = 315-340, in increment of 5)
Maximum system voltage:	1500V
Fuse rating:	20A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I or IIIa
Design load (positive / negative):	3600Pa / 1600Pa
Safety factors:	1.5
Fire safety class:	Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

Module types:	<b>PV Modules with half-cut 7" Mono-crystalline Silicon Solar Cells:</b> 144 cells: SK9612MHVC-xxx (xxx = 525-550, in increment of 5) 132 cells: SK9611MHVC-xxx (xxx = 480-500, in increment of 5) 120 cells: SK9610MHVC-xxx (xxx = 440-455, in increment of 5)
Maximum system voltage:	1500V
Fuse rating:	25A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I or IIIa
Design load (positive / negative):	3600Pa / 1600Pa
Safety factors:	1.5
Fire safety class:	Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)



Module types:	<b>PV Modules with half-cut 8" Mono-crystalline Silicon Solar Cells:</b> 120 cells: SKA610MHVC-xxx (xxx = 585-605, in increment of 5)
Maximum system voltage:	1500V
Fuse rating:	30A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I or IIIa
Design load (positive / negative):	3600Pa / 1600Pa
Safety factors:	1.5
Fire safety class:	Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

Remark:

For detailed product information, please refer to CDF (Constructional Data Form) in Annex 1 of test report.

