A&ZMED
Personal Protective Equipment

HIGH EFFICIENCY FILTRATION

BRETHABLE AND COMFORTABLE

SAFETY PROTECTION



TECHNICAL DATASHEET
A&ZMED Mask FFP2

SCOPE

The technical file covers the quality and factory manufacturing control requirements used during the manufacture of Respiratory Protective Devices - Filtering Half Masks for Protection Against Particles, compliance with the essential health and safety requirements associated with the European Union Directive 2016/425/EU Provisions.
"İbişler Tekstil San. Ve Dış Tic. A.Ş. " Technical File;
EN 149: 2001 + A1: 2009 Respiratory protective devices - Filtering half masks to protect against particles - Requirements, testing, marking It has been prepared for the evaluation of the conformity of the standard.
Referenced standart sor documents;

INSTRUCTIONS FOR USE

1. Shape the mask into a dome shape with the nose clip on top and take it in your palm.
2. Mask; It is worn by holding the tires so that the strip on the upper side is on the bridge of the nose.
3. The rubber is placed on the auricle.
4. Adjust the nose clip by using both hands, tightening it according to your nose shape. Adjusting by compression with one hand can reduce the effect of the mask.
5. To understand the fit and tightness of the mask, take a deep breath and check that no air is entering around the nose. For this, readjust the nose clip if necessary. Then enter the area of work you work in.

IMPORTANT!

It is very important that users are trained in the correct use of the product. If there is difficulty in breathing or the mask is damaged or deformed, or if the face is not suitable, the mask should be changed immediately. Carefully following the instructions is an important step in safe mask use.

PRE-USE CHECKS:

1. Please read the instruction carefully before using.
2. Check the expiry date of the product.
3. Check the fit of the mask to the area used by looking at the markings on the mask.
4. Check the mask headbands.
5. Check the mask nose clip.
6. Check if the mask is damaged

CONFORMITY CHECK

With both hands, grasp the product from the front so as not to affect the fit of the mask on the face.
a) VALVE-FREE Masks, Breathe Strongly
b) VALVE Masks, Breathe Strongly
If there is leakage around the nose, readjust the nose clips to eliminate the leak. Then repeat the above steps. If there is leakage from the mask edges, make sure the head straps are fitted correctly to eliminate the leak. Then repeat the above process. If the necessary compliance cannot be achieved despite all procedures, do not enter the danger zone. Consult your supervisors.

STORAGE

- It should be kept in its original packaging.
- The temperature of the storage area should be between 20 ° C / + 40 °C.
- Ambient Humidity should not be more than 80%.
- Half masks should be protected against the effects of aggressive chemicals, moisture and dirt.
- Half masks are disposable and maintenance free.
- If the above conditions are met, the shelf life is 2 years.

SECURITY PRECAUTIONS

- Failure to follow instructions and restrictions on the use of this product may reduce the effectiveness of the mask and cause illness or death.
- A properly selected mask should be used for your respiratory safety. Before using your product, it is recommended to consult a Workplace Physician or Occupational Safety Specialist about the suitability of the product for your intended use.
- Your product does not provide oxygen. Use only in environments with sufficient oxygen. Do not use this product when the oxygen concentration is less than 19.5%.
- Do not use this product in places containing hazardous contents.
- Do not use this product in explosive atmospheres.
- a) if breathing becomes difficult (b) if dizziness or other discomfort occurs, leave the work area immediately and go to fresh air.
- It is important that the mask fits your face well for full performance. Beard can prevent this. Wear the mask without a beard.
- Never alter or modify the mask.
- The NR marked masks are for single use only. It does not require maintenance. Please do not reuse the mask after a single use.
- Keep the masks away from direct sunlight until the moment of use.



ISO-9001:2015 ISO-13485:2016

CE 2163

FDA

İBİŞLER TEKSTİL SANAYİ VE DIŞ TİC. A.Ş.
Orhangazi Mah. Tunç Cad. No:5 34538 Esenyurt / İstanbul - TURKEY
+90 212 602 04 05 www.ibisler.com info@ibisler.com

8 682742 370744

UNIVERSAL

UNIVERSAL
CERTIFICATION

NB 2163

EU TYPE EXAMINATION CERTIFICATE

Certificate No: 2163-PPE-1306

Respiratory protective devices, filtering half masks to protect against particles manufactured by

İbişler Tekstil Sanayi ve Dış Tic. A.Ş.

Orhan Gazi Mah Tunç Cad. B No:5 B Esenyurt İstanbul TURKEY
are tested and evaluated according to

EN 149:2001 + A1:2009 Respiratory Protective Devices - Filtering Half Masks to Protect Against Particles - Requirements, Testing, Marking

Based on the type examination conducted with the evaluation of test reports, technical file according to Personal Protective Equipment Regulation (EU) 2016/425 Annex 5, it is approved that the product meets the requirements of the regulation.

Product Definition

Brand Name: A&Z MED **Model:** OLI 2025
Filtering half mask
Classification: FFP2 NR

Here the manufacturer is allowed to use notified body number (2163) and can fix CE mark, as shown below, on the Category III product models given above with;

Issuing an appropriate EU Declaration of Conformity according to **Personal Protective Equipment Regulation (EU) 2016/425 Annex 9.**

- Ongoing successful performance surveillance of the requirements of the Personal Protective **Equipment Regulation (EU) 2016/425** and harmonised standards, ensured by assessments based on **Annex 7 (Module C2) or Annex 8 (Module D)** of the regulation no later than 1 year from the beginning of serial production

This certificate is initially issued on **18/08/2020** and will be valid for 5 years, if there is no change in the relevant harmonised standard affecting the essential health and safety requirements.

CE
2163

Suat KAÇMAZ
UNIVERSAL CERTIFICATION
Director

Verify the validity with the QR code

Necip Fazıl Bulvarı Keyap Sitesi E2 Blok No:44/84 Yukarı Dudullu Ümraniye - İSTANBUL - TURKEY T:+90 216 455 80 80
UNIVERSALCERT.COM

This is to Certify that

BVCS
BRITISH VERITAS CERTIFICATION SERVICES

A&Z A&ZMED

İBİŞLER TEKSTİL SAN. VE DIŞ TİC. A.Ş.

ORHANGAZİ MAH. TUNÇ CAD. NO:5/B ESENYURT / İSTANBUL,TURKEY

Conforms to the Requirements of

ISO 9001:2015

Quality Management System

Tulum ve Medikal Maske Dikimi ve Satışı.

Jumpsuit and Medical Mask Sewing and Sale .

Certificate Number : Q.020.080.TR
Certification Period : 3 Years / 16.04.2023

Expiry Date : 17.04.2023
Certified Date : 17.04.2020

Approving Officer:

A. Ozgun

BRITISH VERITAS CERTIFICATION SERVICES
BVCS
CERTIVICATION
www.bvcscert.com

HMI Certification Training Ltd.
492 Bearwood Rd, Smethwick B66 4HB, Birmingham / West Midland - England
This certificate remains the property of HMI it is valitidy is subject to arrangement between the certificated client and HMI. For further detalis go to
www.bvcscert.com

This is to Certify that

BVCS
BRITISH VERITAS CERTIFICATION SERVICES

A&Z A&ZMED

İBİŞLER TEKSTİL SAN. VE DIŞ TİC. A.Ş.

ORHANGAZİ MAH. TUNÇ CAD. NO:5/B ESENYURT / İSTANBUL,TURKEY

Conforms to the Requirements of

ISO 13485:2016

Medical Device Quality Management System

Tulum , Medikal Önlük ve Medikal Maske Dikimi ve Satışı.

Jumpsuit,Medical Gowns and Medical Mask Sewing and Sale .

Certificate Number	: M.020.080.TR	**Expiry Date**	: 17.04.2023
Certification Period	: 3 Years / 16.04.2023	**Certified Date**	: 17.04.2020

Approving Officer:

BRITISH VERITAS CERTIFICATION SERVICES
BVCS
CERTIVICATION
www.bvcscert.com

HMI Certification Training Ltd.
492 Bearwood Rd, Smethwick B66 4HB, Birmingham / West Midland - England
This certificate remains the property of HMI it is volitidy is subject to arrangement between the certificated client and HMI. For further details go to
www.bvcscert.com

Article 7.17	**Clogging:** This test is not applied to Particle Filtering Half Mask which is not reusable. *(For single shift use devices, the clogging test is optional test. For re-usable devices test is mandatory.)*
Article 7.18	**Demountable Parts:** There are no demountable parts on the product.
Article 8	**Testing:** All tests conducted according to Clause 8 of this standard is available in the test report and are evaluated in this report for qualification and classification of the mask.
Article 9	**Marking – Packaging:** Necessary markings are available on the product package (box). The manufacturer and its trademark is clearly visible. The type of the mask and the classification including the status of re-usability, the reference to EN 149:2001+A1:2009 standard, the end date of shelf life, using and storage instructions and pictograms and CE mark are available on the product package. The above evaluation is based on the technical document for packaging and marking, for box design. Verified on the technical file. The technical documentation for mask design (drawing) also evaluated for marking requirements, drawing OLI 2025. The mask template (drawing) indicates that the mask will carry information about the manufacturer type of mask, the reference to EN 149+A1:2009 standard and classification including the re-usability of the mask. The manufacturer also printed CE mark with our Notified Body number. The mask do not have sub-assemblies. The marking statement given in the technical documentation was not available on the tested specimen, the manufacturer shall consider to use the marking as stated in the technical file in case of serial manufacturing. Model OLI 2025 drawing exists in the technical file of the manufacturer.
Article 10	**Information to be supplied by the manufacturer:** In each of the smallest commercially available packaging of the product, implementation (installation instructions) pre-use controls, warning and usage limitations, storage and meanings of symbols / pictograms are defined. User instruction document in the technical file found to be appropriate. The manufacturer shall include this documented user information text in every smallest commertially available package.

PREPARED BY	APPROVED BY
Osman CAMCI PPE Expert	**Suat KAÇMAZ** General Manager

UNIVERSAL CERTIFICATION CE 2163 Notified Body

UNIVERSAL SERTİFİKASYON VE GÖZETİM HİZM. TİC. LTD. ŞTİ. Keyap Ticaret Merkezi, Necip Fazıl Bulvarı, E2 Blok, No:44/84 Y. Dudullu - Ümraniye - İSTANBUL T:+90 216 455 80 80 F:+90 216 455 80 08 info@universalcert.com

UNIVERSAL
CERTIFICATION

UNIVERSAL CERTIFICATION and SURVEILLANCE SERVICES TRADE CO.
Necip Fazil Bulvari Keyap Sitesi E2 Blok No:44/84 Yukari Dudullu Umraniye, Istanbul / TURKEY

TEST REPORT

Report Date: 17.08.2020
Report Number: 08-2020-T-0309

CLIENT and SAMPLE INFORMATION

TEST OWNER	İBİŞLER TEKSTİL SANAYİ VE DIŞ TİC. A.Ş.		
ADDRESS	ORHAN GAZİ MAH TUNÇ CAD. B NO:5 B ESENYURT İSTANBUL		
SAMPLE DESCRIPTION	Folding type protective mask		
BRAND NAME – MODEL	A&Z MED / OLI 2025		
TESTING STANDARD	EN 149+A1:2009		
CASE NUMBER	CE-PPE-3315		
SAMPLE RECEIVE DATE	20.07.2020	TESTING START DATE	20.07.2020
DISINFECTION INSTRUCTION *If applicable*	Not given, single use only		
NUMBER OF SAMPLES	50	SAMPLE IDs:	1 – 46
AS RECEIVED SAMPLE NO	26-46		
CONDITIONING SAMPLE NO	Simulated wearing treatment	1-2-3-4-5-6-7-8-9 (As Received)	
	Temperature conditioning	10-11-12-13-14-15 (Sample after test of Mechanical Strength)	
		16-17-18-19-20-21-22-23-24-25 (As Received)	
	Mechanical strength	10-11-12-13-14-15 (As Received)	

The results given in this test report belongs to the samples tested. The report content cannot be recreated partially without the written consent of UNIVERSAL CERTIFICATION.

UNIVERSAL SERTİFİKASYON VE GÖZETİM HİZM. TİC. LTD. ŞTİ.
Necip Fazıl Bulvarı, Keyap Sitesi, E2 Blok, No:44/84
Yukarı Dudullu-Ümraniye/İSTANBUL
Telefon: 0216 455 80 80 Faks: 0216 455 80 08
Sarıgazi V.D. 892 025 8722

Suat KAÇMAZ
Director

1. *REPORT SUMMARY*

TEST STANDARD	*TEST NAME*	*RESULT*	*EVALUATION*
EN 149:2001 + A1:2009 clause 8.5 EN 13274-1:2001	Total Inward Leakage Testing	**Pass**	**FFP2**
EN 149:2001 + A1:2009 clause 8.11 EN 13274-7:2019	Penetration of Filter Material	**Pass**	**FFP2**
EN 149:2001 + A1:2009 clause 8.6 EN 13274-4:2001	Flammability Testing	**Pass**	**See results**
EN 149:2001 + A1:2009 clause 8.7 EN 13274-6:2001	Carbon Dioxide Content of The Inhalation Air Testing	**Pass**	**See results**
EN 149:2001 + A1:2009 clause 8.9 EN 13274-3:2001	Breathing Inhalation Resistance-30 l/min	**Pass**	**See results**
	Breathing Inhalation Resistance-95 l/min	**Pass**	**See results**
EN 149:2001 + A1:2009 clause 8.9 EN 13274-3:2001	Exhalation Resistance, flow rate 160 l/min	**Pass**	**See results**

UNIVERSAL CERTIFICATION
UNIVERSAL SERTİFİKASYON VE GÖZETİM HİZM. TİC. LTD. ŞTİ.
Necip Fazıl Bulvarı, Keyap Sitesi, E2 Blok, No:44/84
Yukarı Dudullu-Ümraniye/İSTANBUL
Telefon: 0216 455 80 80 Faks: 0216 455 80 08
Sarıgazi V.D. 892 025 8722

2. *TEST RESULTS and EVALUATION*

7.4 PACKAGING (EN 149:2001 + A1:2009 clause 8.2)

Test Method: Clause 8.2-Visual inspection

REQUIREMENT	RESULTS	COMMENT
Particle filtering half masks shall be offered for sale packaged in such a way that they are protected against mechanical damage and contamination before use.	Pass	The masks were packaged in sealed plastic bags, in larger plastic bags inside a large cardboard box that gave some protection against mechanical damage or contamination before use

Lab A

7.5 MATERIAL (EN 149:2001 + A1:2009 clause 8.2, 8.3.1, 8.3.2)

Test Method: Clause 8.2-Visual inspection

Clause 8.3.1-Simulated wearing treatment

A breathing machine is adjusted to 25 cycles/min and 2,0 l/stroke. The particle filtering half mask was mounted on a Sheffield dummy head.

For testing, a saturator is incorporated in the exhalation line between the breathing machine and the dummy head, the saturator being set at a temperature in excess of 37 °C to allow for the cooling of the air before it reaches the mouth of the dummy head.

The air has been saturated at (37 ± 2) °C at the mouth of the dummy head

Clause 8.3.2-Temperature conditioning

The ambient temperature for testing has been between 16 °C and 32 °C and the temperature limits has been subject to an accuracy of ±1 °C.

a) for 24 h to a dry atmosphere of (70 ± 3) °C;

b) for 24 h to a temperature of (-30 ± 3) °C; and allow to return to room temperature for at least 4 h between exposures and prior to subsequent testing. The conditioning has been carried out in a manner which ensures that no thermal shock occurs.

REQUIREMENT	RESULTS	COMMENT
Materials used shall be suitable to withstand handling and wear over the period for which the particle filtering half mask is designed to be used.	Pass	The materials used were able to withstand handling and wear during the limited laboratory testing carried out.
Any material from the filter media released by the air flow through the filter shall not constitute a hazard or nuisance for the wearer.	Pass	It was not constitute a hazard or nuisance for the wearer.
After undergoing the conditioning described in 8.3.1 none of the particle filtering half masks shall have suffered mechanical failure of the facepiece or straps.	Pass	None of the specimens conditioned suffered mechanical failure.
When conditioned in accordance with 8.3.1 and 8.3.2 the particle filtering half mask shall not collapse.	Pass	None of the specimens had not collapse after conditioning.

Lab B

UNIVERSAL CERTIFICATION
UNIVERSAL SERTİFİKASYON VE GÖZETİM HİZM. TİC. LTD. ŞTİ.
Necip Fazıl Bulvarı, Keyap Sitesi, E2 Blok, No:44/84
Yukarı Dudullu-Ümraniye/İSTANBUL
Telefon: 0216 455 80 80 Faks: 0216 455 80 08
Sarıgazi V.D. 892 025 8722

7.6 CLEANING AND DISINFECTING (EN 149:2001 +A1:2009 clause 8.4, 8.5, 8.11)

Test Method: Described in Clause 8.4, 8.5 and 8.11

REQUIREMENT	RESULTS	COMMENT
If the particle filtering half mask is designed to be re-usable, the materials used shall withstand the cleaning and disinfecting agents and procedures to be specified by the manufacturer. With reference to 7.9.2, after cleaning and disinfecting the re-usable particle filtering half mask shall satisfy the penetration requirement of the relevant class.	N/A	This article is not applicable for tested protective mask which is single use disposable mask.

7.7 PRACTICAL PERFORMANCE (EN 149:2001 + A1:2009 clause 8.4)

Test Method: Described in Clause 8.4

REQUIREMENT	RESULTS	COMMENT
The particle filtering half mask shall undergo practical performance tests under realistic conditions. These general tests serve the purpose of checking the equipment for imperfections that can not be determined by the tests described elsewhere in this standard. Two as received mask samples are used by two subject for the walking (10 mins walking with a speed of 6km/h) and work simulation (bended walking, crawling and basket filling exercises) tests.	No imperfections	Detail refer to Annex I

Annex I-Test Result:

Number of sample: 29 (A.R), 30 (A.R)

Assessed elements	Positive Assessment	Negative Assessment	Requirements in accordance with EN 149:2001+A1:2009	Assessment of Test Result Conformity / Nonconformity
The face piece fitting Head harness comfort Security of fastenings Field of vision	2 2 2 2	0 0 0 0	Filtering half masks should not have imperfections related to wearer's acceptance	Filtering half masks fulfil requirements of the standard EN 149:2001 + A1:2009 given in 7.7 No imperfections

The subjects (MEG and MA) were able to complete the exercises and did not report any nuisance or problem with the mask.

Lab B

7.8 FINISH OF PARTS (EN 149:2001 + A1:2009 clause 8.2)

Test Method: Described in Clause 8.2

REQUIREMENT	RESULTS	COMMENT
Parts of the device likely to come into contact with the wearer shall have no sharp edges or burrs.	Pass	None of the specimens used in laboratory testing showed evidence of sharp edges or burrs while visual inspection and performance tests.

Lab A

UNIVERSAL CERTIFICATION
UNIVERSAL SERTİFİKASYON VE GÖZETİM HİZM. TİC. LTD. ŞTİ.
Necip Fazıl Bulvarı, Keyap Sitesi, E2 Blok, No:44/84
Yukarı Dudullu-Ümraniye/İSTANBUL
Telefon: 0216 455 80 80 Faks: 0216 455 80 08
Sarıgazi V.D. 892 025 8722

7.9.1 TOTAL INWARD LEAKAGE (EN 149:2001+A1:2009 clause 8.5)

Test Method: Described in Clause 8.5

REQUIREMENT	RESULTS	COMMENT
The total inward leakage consists of three components: face seal leakage, exhalation value leakage (if exhalation value fitted) and filter penetration. For particle filtering half masks fitted in accordance with the manufacturer's information, at least 46 out of the 50 individual results shall be not greater than: 25 % for FFP1, 11 % for FFP2, 5 % for FFP3 and in addition at least 8 out of the 10 individual wearer arithmetic means for the total inward leakage shall not be greater than: 22 % for FFP1, 8 % for FFP2, 2 % for FFP3	Pass	Classified as FFP2 Detail refer to Annex II

Annex II-Test Result:

The test results obtained are given in the tables as follows

Test Subject	No of sample	Cond.	1. Walk (%)	Head side/ side (%)	Head up/down (%)	Talk (%)	2. Walk (%)	Average (%)
1	31	A.R.	5,37	5,93	5,15	6,40	6,03	5,78
2	32	A.R.	4,58	4,76	5,92	5,98	4,60	5,17
3	33	A.R.	6,00	6,20	4,60	4,72	4,67	5,24
4	34	A.R.	4,84	5,88	6,02	5,59	5,53	5,57
5	35	A.R.	4,91	6,23	5,27	6,27	5,67	5,67
6	16	T.C.	4,87	4,75	5,71	5,25	6,37	5,39
7	17	T.C.	6,51	5,32	4,90	6,48	5,71	5,78
8	18	T.C.	5,43	6,26	5,26	6,08	5,38	5,68
9	19	T.C.	6,34	5,10	6,30	5,94	6,30	5,99
10	20	T.C.	6,17	5,42	5,87	5,91	6,06	5,89
All 50 individual exercise results were not greater than 11 % All 10 individual wearer arithmetic means were not greater than 8 %.								Pass (FFP2)

Test Subject	Face Length (mm)	Face Width (mm)	Face Depth (mm)	Mouth Width (mm)
1	117	155	130	60
2	113	148	128	62
3	112	160	134	59
4	115	148	125	61
5	120	158	132	57
6	118	150	134	59
7	115	152	130	57
8	117	155	134	59
9	114	149	128	57
10	110	150	131	55

For Information Only

Lab B

UNIVERSAL CERTIFICATION
UNIVERSAL SERTİFİKASYON VE GÖZETİM HİZM. TİC. LTD. ŞTİ.
Necip Fazıl Bulvarı, Keyap Sitesi, E2 Blok, No:44/84
Yukarı Dudullu-Ümraniye/İSTANBUL
Telefon: 0216 455 80 80 Faks: 0216 455 80 08
Sarıgazi V.D. 892 025 8722

7.9.2 PENETRATION OF FILTER MATERIAL (EN 149:2001+A1:2009 clause 8.11)

Test Method: Described in Clause 8.11

REQUIREMENT	RESULTS	COMMENT
See table below	Pass	Detail refer to Annex IIIA and IIIB

Classification	Max penetration of test aerosol	
	NaCl test 95 l/min %max	Paraffin oil test 95 l/min %max
FFP1	20	20
FFP2	6	6
FFP3	1	1

Annex IIIA-Test Result:

The test results obtained are given in the tables as follows:

No. of Sample	Condition	Penetration of Sodium Chloride in accordance with EN 13274-7:2019 [%] Flow rate 95 l/min	Requirements in accordance with EN 149:2001+A1:2009	Assessment of Test Result Conformity / Nonconformity
36	As received	0,83	FFP1 ≤ 20 % FFP2 ≤ 6 % FFP3 ≤ 1 %	Passed Filtering half masks fulfil the requirements of the standard EN 149:2001+A1:2009 given in 7.9.2 in range of the first, second protection class (FFP1, FFP2)
37		0,87		
38		0,66		
1	Simulated wearing treatment	0,70		
2		1,09		
3		0,72		
10	Mechanical strength + Temperature conditioned	0,50		
11		0,78		
12		1,09		

Annex IIIB-Test Result:

The test results obtained are given in the tables as follows:

No. of Sample	Condition	Penetration of Paraffin Oil Mist in accordance with EN 13274-7:2019 [%] Flow rate 95 l/min	Requirements in accordance with EN 149:2001+A1:2009	Assessment of Test Result Conformity / Nonconformity
39	As received	1,62	FFP1 ≤ 20 % FFP2 ≤ 6 % FFP3 ≤ 1 %	Passed Filtering half masks fulfil the requirements of the standard EN 149:2001+A1:2009 given in 7.9.2 in range of the first, second protection classes (FFP1, FFP2)
40		1,14		
41		1,96		
4	Simulated wearing treatment	1,70		
5		1,65		
6		1,61		
13	Mechanical strength + Temperature conditioned	1,66		
14		1,39		
15		1,98		

Lab A + B

UNIVERSAL CERTIFICATION
UNIVERSAL SERTİFİKASYON VE GÖZETİM HİZM. TİC. LTD. ŞTİ.
Necip Fazıl Bulvarı, Keyap Sitesi, E2 Blok, No:44/84
Yukarı Dudullu-Ümraniye/İSTANBUL
Telefon: 0216 455 80 80 Faks: 0216 455 80 08
Sarıgazi V.D. 892 025 8722

7.10 COMPATIBILITY WITH SKIN (EN 149:2001 + A1:2009 clause 8.4, 8.5)

Test Method: Described in Clause 8.4 and 8.5.

REQUIREMENT	RESULTS	COMMENT
Materials that may come into contact with the wearer's skin shall not be known to be likely to cause irritation or any other adverse effect to health.	Pass	No irritation or any other adverse effect to health or sensitivity reported by the subjects during the practical performance and TIL tests.

Lab B

7.11 FLAMMABILITY (EN 149:2001 + A1:2009 clause 8.6)

Test Method: Described in Clause 8.6

REQUIREMENT	RESULTS	COMMENT
The material used shall not present a danger for the wearer and shall not be of highly flammable nature. When tested, the particle filtering half mask shall not burn or not to continue to burn 5s after removal from the flame.	Pass	Detail refer to Annex IV

Annex IV-Test Result: The test results obtained are given in the tables as follows:

No. of Sample	Condition	Visual inspection	Requirements in accordance with EN 149:2001+A1:2009	Assessment of Test Result Conformity / Nonconformity
45	As received	0,3 s	Filtering half mask shall not burn or not continue to burn for more than 5 s after removal from the flame	Passed Filtering half masks fulfil requirements of the standard EN 149:2001 + A1:2009 given in 7.11
46		0,3 s		
21	Temperature conditioned	0,5 s		
22		0,4 s		

Lab B

7.12 CARBON DIOXIDE CONTENT OF THE INHALATION AIR (EN 149:2001 + A1:2009 clause 8.7)

Test Method: Described in Clause 8.7

REQUIREMENT	RESULTS	COMMENT
The carbon dioxide content of the inhalation air (dead space) shall not exceed an average of 1,0 % (by volume)	Pass	Detail refer to Annex V

Annex V-Test Result: The test results obtained are given in the tables as follows:

No. of Sample	Condition	CO_2 content of the inhalation air [%] by volume	An average CO_2 content of the inhalation air [%] by volume	Requirements in accordance with EN 149:2001+A1:2009	Assessment of Test Result Conformity / Nonconformity
26	As received	0,64	0,71	CO_2 content of the inhalation air shall not exceed an average of 1,0% by volume	Passed Filtering half masks fulfil requirements of the standard EN 149:2001 + A1:2009 given in 7.12
27		0,75			
28		0,74			

Lab B

UNIVERSAL CERTIFICATION
UNIVERSAL SERTİFİKASYON VE GÖZETİM HİZM. TİC. LTD. ŞTİ.
Necip Fazıl Bulvarı, Keyap Sitesi, E2 Blok, No:44/84
Yukarı Dudullu-Ümraniye/İSTANBUL
Telefon: 0216 455 80 80 Faks: 0216 455 80 08
Sarıgazi V.D. 892 025 8722

7.13 HEAD HARNESS (EN 149:2001 + A1:2009 clause 8.4, 8.5)

Test Method: Described in Clause 8.4, 8.5

REQUIREMENT	RESULTS	COMMENT
The head harness shall be designed so that the particle filtering half-mask can be donned and removed easily.	Pass	No problem with the head harness reported by the wearers during the practical performance test.
The head harness shall be adjustable or self-adjusting and shall be sufficiently robust to hold the particle filtering half mask firmly in position and capable of maintaining total inward leakage requirements for the device.	Pass	No problem with the head harness reported by the wearers during the practical performance test.

Lab B

7.14 FIELD OF VISION (EN 149:2001 + A1:2009 clause 8.4)

Test Method: Described in Clause 8.4

REQUIREMENT	RESULTS	COMMENT
The field of vision is acceptable if determined so in practical performance tests.	Pass	There were no adverse comments following practical performance tests.

Lab B

7.15 EXHALATION VALVE (EN 149:2001 + A1:2009 clause 8.2, 8.3.4, 8.8, 8.9.1)

Test Method: Clause 8.2, 8.3.4, 8.8, 8.9.1

REQUIREMENT	RESULTS	COMMENT
A particle filtering half mask may have one or more exhalation valve(s), which shall function correctly in all orientations.	N/A	No exhalation valve in tested samples.
If an exhalation valve is provided it shall be protected against or be resistant to dirt and mechanical damage and may be shrouded or may include any other device that may be necessary for the particle filtering half mask to comply with 7.9	N/A	No exhalation valve in tested samples.
Exhalation valve(s), if fitted, shall continue to operate correctly after a continuous exhalation flow of 300 l/min over a period of 30s.	N/A	No exhalation valve in tested samples.
When the exhalation valve housing is attached to the face blank, it shall withstand axially a tensile force of 10N applied for 10s.	N/A	No exhalation valve in tested samples.

Lab -

UNIVERSAL CERTIFICATION
UNIVERSAL SERTİFİKASYON VE GÖZETİM HİZM. TİC. LTD. ŞTİ.
Necip Fazıl Bulvarı, Keyap Sitesi, E2 Blok, No:44/84
Yukarı Dudullu-Ümraniye/İSTANBUL
Telefon: 0216 455 80 80 Faks: 0216 455 80 08
Sarıgazi V.D. 892 025 8722

7.17 CLOGGING (EN 149:2001 + A1:2009 clause 8.9, 8.10)

Test Method: Described in Clause 8.8, 8.10

REQUIREMENT	RESULTS	COMMENT
Valved particle filtering half masks: After clogging the inhalation resistances shall not exceed: FFP1:4mbar, FFP2:5mbar, FFP3:7mbar at 95L/min continuous flow. The exhalation resistance shall not exceed 3mbar at 160L/min continuous flow. Valveless particle filtering half masks: After clogging the inhalation resistances shall not exceed: FFP1:3mbar, FFP2:4mbar, FFP3:5mbar at 95L/min continuous flow	NAs	This is optional test and not desired by client.

Lab -

7.18 DEMOUNTABLE PARTS (EN 149:2001 + A1:2009 clause 8.2)

Test Method: Described in Clause 8.2

REQUIREMENT	RESULTS	COMMENT
All demountable parts (if fitted) shall be readily connected and secured, where possible by hand	N/A	No demountable part.

Lab -

Pass	*Requirement satisfied.*
NCR	*Requirement not satisfied. Refer to the "Result details" section for more information.*
NAs	*Assessment not carried out.*
N/A	*Requirement not applicable.*

LABORATORY INFORMATION

Code	Laboratory Name	Competency Explanations
Lab A	UNIVERSAL SERTIFIKASYON VE GOZETIM HIZMETLERI TIC. LTD. STI.	Internal Laboratory Services of Notified Body
Lab B	GCNTR ULUSLARARASI BELGELENDIRME, GOZETIM, EGITIM VE DIS TICARET LIMITED SIRKETI KOCAELI DILOVA SUBESI	Laboratory holds an accreditation by Turkish Accreditation Agency with number AB-1252-T according to EN ISO/IEC 17025:2017.

- The laboratories are contracted bodies with UNIVERSAL CERTIFICATION and the technical competence of the laboratories is also under supervision / assessment of UNIVERSAL CERTIFICATION based on the provisions of EN ISO/IEC 17065 Requirements for bodies certifying products, processes and services standard.
- Each test result given in this test report shown with the issuing laboratory code.

UNIVERSAL CERTIFICATION
UNIVERSAL SERTİFİKASYON VE GÖZETİM HİZM. TİC. LTD. ŞTİ.
Necip Fazıl Bulvarı, Keyap Sitesi, E2 Blok, No:44/84
Yukarı Dudullu-Ümraniye/İSTANBUL
Telefon: 0216 455 80 80 Faks: 0216 455 80 08
Sarıgazi V.D. 892 025 8722

Sample Photo

- End of Report -

UNIVERSAL
CERTIFICATION
UNIVERSAL
SERTİFİKASYON
VE GÖZETİM HİZM.
TİC. LTD. ŞTİ.
Necip Fazıl Bulvarı, Keyap Sitesi, E2 Blok, No:44/84
Yukarı Dudullu-Ümraniye/İSTANBUL
Telefon: 0216 455 80 80 Faks: 0216 455 80 08
Sarıgazi V.D. 892 025 8722